



CUSTOM ELECTRICAL INSULATION

Test report - filament wound epoxy fiberglass bushing tube

SINCE 2017

ISO 9001

OEM / ODM

Well Electric - WELLELE

No. 196 Yingchun Road, Suzhou, Jiangsu, China

Tel +86 512 6708 1529 - sale@wellele.com - www.wellele.com

Filament Wound Tube/Epoxy Fiberglass Bushing

Test Report

category	parameter			
Temperature resistance	130℃			
Product appearance color	Gray, red, black			
Inner diameter range	6~50 (Can be customized according to customer)			
Length range	0~1400 (Can be customized according to customer)			
Surface finish	Polishing, grinding, rolling flowers, etc. (Can be processed according to customer requirements)			
mechanical strength	high			
Performance test data				
Serial number	Test item	Company	index	Remarks
1	density	g/cm3	1.38—1.45	
2	24h water absorption	%	30—40%	



TEL:+86-512-67081529 FAX:+86-512-65256838
E.mail:sale@wellele.com,info@wellele.com
http://www.wellele.com,allinsulating.com,fusestube.com
Add:suli RD47.Caizhi 5-712, SUZHOU, JIANGSU

3	Axial transverse tensile strength	Mpa	650—700	
4	Voltage perpendicular to the wall	Kv	9—11	
5	Zinc chloride content	%	≤0.07	
6	ash content	%	≤1.2	
6	Water content	%	5--8	
Note: the above test data for the sample test data, our company can customize products according to customer needs.				

WELL ELECTRIC CO.LTD www.wellele.com